

NAVSEA
STANDARD ITEM

FY-11

ITEM NO: 009-34
DATE: 24 JUL 2009
CATEGORY: I

1. SCOPE:

1.1 Title: Fire Protection of Unmanned Vessels at Contractor's Facility;
provide

2. REFERENCES:

2.1 NFPA Standard 312, Standard for Fire Protection of Vessels During
Construction, Repair, and Lay-up

2.2 29 CFR Part 1915, Occupational Safety and Health Standards for
Shipyard Employment

3. REQUIREMENTS:

3.1 Provide fire protection in accordance with the requirements of 2.1 and
2.2 and this item.

3.2 Maintain available for review, prior to commencement of work, a fire
safety plan meeting the requirements of 2.2. In addition to the requirements
of 2.2, the plan shall include and identify the method for reporting fires,
the shipyard fire fighting facilities, equipment, and organization (paid or
volunteer), the procedures for maintenance of clear fire lanes in the shipyard
and on the piers, and the nearest municipal fire fighting organization,
including the anticipated time of response.

3.3 Provide fire protection equipment consisting of:

3.3.1 Fire-fighting water, utilizing manifolds connected to a source
capable of providing 150 GPM at 60 PSIG at the manifold shall be in place
before start of work.

3.3.1.1 The number of manifolds shall be sufficient to permit
reaching all points on the vessel (including underwater body when the vessel
is in dry dock or on a marine railway) with 2, 1-1/2 inch hoses of not more
than 100 feet in length.

3.3.1.2 Hoses shall be attached to the manifolds and fitted
with an all-purpose combination fog and straight stream nozzle.

3.3.1.3 Verify by the Pitot tube method or an in-line flow meter that the water volume and pressure meets these requirements.

4. NOTES:

4.1 *The term "unmanned" is defined as without the physical presence of people in control; without a human operator.*